

CERTIFICATE OF CONFORMITY

Certificate No.: LC20173-1

Date Issued: August 12, 2021

Project No.: 20173

Certification System: Type 3
(ISO / IEC 17067)

Client No.: LC1231751

Applicant: Victron Energy B.V.
De Paal 35
1351 JG Almere Haven
Netherlands



Issued by:

Certification Manager

Products:

- Inverter
- Model Nos.: MultiPlus Compact 12 | 2000 | 80-50 120V
- Ratings:

INVERTER	
Input voltage range (V DC)	9,5 – 17
Output	Output voltage: 120 VAC \pm 2% Frequency: 60 Hz \pm 0,1% (can be adjusted to 50Hz)
Cont. output power at 25°C (VA) (non linear load, crest factor 3:1)	2000
Cont. output power at 25°C (W)	1600
Cont. output power at 40°C (W)	1450
Cont. output power at 65°C (W)	1100
Peak power (W)	4000
CHARGER	
AC Input	Input voltage range: 95-140 VAC Input frequency: 45 – 65 Hz Power factor: 1
Charge voltage 'absorption' (V DC)	14,4 / 28,8
Charge voltage 'float' (V DC)	13,8 / 27,6
Storage mode (V DC)	13,2 / 26,4
Charge current house battery (A) (at 25°C ambient)	80

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.

Applicant: Victron Energy B.V.

Certificate No.: LC20393-1

Applicable requirements:

- UL 458 6th Edition

Conditions of acceptability:

- None

General Note:

- Refer to LC Listing Report No. 10.00.20393-1_Rev0



ISO 17020

ISO 17025

ISO 17065

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.